

**SECTION 09624 – MODULAR ATHLETIC FLOORING**

**PART 1 - GENERAL**

**1.1 DESCRIPTION**

- A. Scope
  - 1. The complete installation of modular sports surfacing system including the interlocking suspended high-impact polypropylene copolymer tile of proprietary formulation, supportive acoustical underlayment and striping.
- B. Related work specified under other sections.
  - 1. CONCRETE SUBFLOORS - SECTION 03 00 00
    - a. The general contractor shall furnish and install the concrete subfloors.
    - b. The slab shall be steel troweled to a medium-dense finish to a tolerance of  $\pm 1/8"$  (3.2mm) in any 10' (3m) radius. Floor Flatness and Floor Levelness (FF and FL) numbers are not recognized. High spots shall be ground level and low spots filled with approved leveling compound.
  - 2. GAME STANDARD INSERTS - SECTION 11 66 00

**1.2 REFERENCES**

- A. ASTM (American Society for Testing & Materials)
  - 1. ASTM G-21
  - 2. ASTM D4060
- B. DIN (Deutsches Institut für Normung)
  - 1. DIN 18032-2
- C. GMW (General Motors Worldwide Standards)
  - 1. GMN3943 GMW14698
- D. ISO (International Organization for Standardization)
  - 1. ISO 9001:2015
  - 2. ISO 14001:2015

**1.3 SUBMITTALS**

- A. Sport Court® Maple Select™ Response HG™ Specifications.
- B. One sample of specified system, if requested by Architect.
- C. Sport Court® Modular Sports Flooring Care and Maintenance Guide.
- D. Sport Court® Maple Select™ Response HG™ Warranty.

**1.4 QUALITY ASSURANCE**

- A. MATERIAL SUPPLIER:
  - 1. Shall be Sport Court® International, Inc. (manufacturer)
  - 2. Manufacturer must be ISO 9001:2015 & ISO 14001:2015 Certified to assure proper quality and environmental control.
  - 3. Manufacturer shall be a Zero Waste™ company.
  - 4. Manufacturer shall have produced sports surfaces for a longer period of time than their stated warranty.
  - 5. Surfaces must be certified for competition by the international federations for basketball (FIBA), and volleyball (FIVB).
  - 6. Product must have factory applied urethane coating.
- B. INSTALLER:
  - 1. The complete installation of the flooring system, as described in these specifications, shall be carried out by an experienced installer (Flooring Contractor), and the work shall be performed in accordance with current installation instructions of Connor Sport Court® International, Inc.
  - 2. Installer (Flooring Contractor) shall be liable for all matters related to installation for a period of one year after the floor has been substantially installed and completed.
  - 3. Successful bidder must submit a minimum of five (5) completed modular projects of similar magnitude and complexity within the last two (2) years.
  - 4. Bidder must provide all sample tile, accessory products, and documentation.

**1.5 DELIVERY, STORAGE AND HANDLING**

- A. Materials must be delivered in manufacturer's original, unopened and undamaged packaging with identification labels intact.
- B. Store material on a clean, dry, and flat surface, protected from exposure to harmful weather conditions or possible damage.
- C. Storage conditions shall be 55°F to 80°F (13°C to 27°C).

**1.6 SITE CONDITIONS**

- A. In order to prevent damage and not void the warranty, installation of modular materials shall not commence until all other finishes and overhead mechanical trades have completed their work in the modular floor areas.
- B. Permanent heat, light and ventilation shall be installed and operating during and after installation.
- C. Subfloors shall be clean, dry and free from dirt, dust, oil, grease, paint, old adhesive residue, or other foreign materials.
- D. Flooring installation shall not begin until the levelness of requirements of concrete subfloors have been met.
- E. The installation area shall be closed to all traffic and activity for a period to be set by the flooring contractor.
- F. Product shall be conditioned at temperatures between 55°F to 80°F (13°C to 27°C) and shall be maintained for 24 hours prior to, during, and 24 hours after installation.
- G. Environmental Limitations
  - 1. Comply with the Sport Court® requirements.
  - 2. Adhere to all SDS requirements for materials employed in the work.
  - 3. Protect all persons from exposure to hazardous materials at all times.
- H. After modular floors are installed and the game lines painted, the area is to be closed to allow curing time for the system, typically 3-5 days. No other trades or personnel are allowed on the floor until it has been accepted by the owner.

**1.7 WARRANTY**

- A. Sport Court® provides a limited warranty of fifteen (15) years on the materials it has supplied. (A copy of the full warranty, with its Terms and Exclusions, is available from the authorized Sport Court® Dealer.) This 15-Year Limited Warranty is subject to the Maple Select™ Response HG™ Flooring Warranty, and all of their provisions. This warranty is expressly limited to the flooring materials (goods) supplied by Sport Court®. During the period covered under this Maple Select™ Response HG™ Flooring Warranty, Sport Court® shall repair/replace any tile(s) with a defective Response HG™ Flooring with the same or substantially similar product according to the schedule in the Maple Select™ Response HG™ Flooring Warranty. This warranty does not cover floor damage caused (wholly or in part) by fire, winds, floods, moisture, UV exposure, other unfavorable atmospheric conditions or chemical action, nor does it apply to damage caused by ordinary wear, misuse, abuse, negligent or intentional misconduct, aging, faulty building construction, concrete slab separation, faulty or unsuitable subsurface or site preparation, settlement of the building walls or faulty or unprofessional installation of Sport Court® flooring systems.
- B. Sport Court® shall not be liable for incidental or consequential losses, damages or expenses directly or indirectly arising from the sale, handling or use of the materials (goods) or from any other cause relating thereto, and their liability hereunder in any case is expressly limited to the replacement of materials (goods) not complying with this agreement or, at their election, to the repayment of, or crediting buyer with, an amount equal to the purchase price of such materials (goods), whether such claims are for breach of warranty or negligence. Any claim shall be deemed waived by buyer unless submitted to Sport Court® in writing within 30 days from the date buyer discovered, or should have discovered, any claimed breach.

**PART 2 - PRODUCTS****2.1 MATERIALS**

- A. Sport Court® Maple Select™ and Response HG™ Patented Suspended Flooring shall be:
  - 1. One piece solid-top design with optional shock absorbing sublayer up to 7mm.
  - 2. Metric-sized: 25cm x 25cm x 12.7mm (9.842" x 9.842" x ½").
  - 3. High-impact polypropylene copolymer suspended modules.
  - 4. 281 individual hexagonal cell support structure.
  - 5. Proprietary Maple or solid color in-mold foil transfer with a multi-layer factory applied, wear resistant polyurethane clear coat.
  - 6. The tile shall have a patented positive locking system.
- B. Standard Colors:
  - 1. Standard Maple Select™ Colors: Light Maple, Dark Maple, Silver Maple, Deep Blue Maple.
  - 2. Standard Response HG™ Colors: Pearl Gold, Pearl Burgundy, Pearl Royal Blue, Silver, Ultra Red, Black, Pearl Graphite, Pearl Beige, Pearl Evergreen, Pearl Navy Blue, Pearl Orange, Pearl Shamrock, Pearl Purple, Ice Blue, Pearl Silver Blue, Yellow.
- C. Color Consistency:  $\Delta E_{CMC} < 1.0$
- D. Weight:  $0.61 \pm 0.01$  lbs. ( $278 \pm 5$  grams)
- E. Packaging: Product is shipped in pre-assembled sheets (2x4 tiles per sheet, 6 sheets per box) or on pallets in pre-assembled 4x4 sheets of 16 tiles.
- F. Product Test Results
  - 1. Force Reduction (DIN 18032-2): 0.08" (2mm underlayment) – 10% - 15%  
(Shock Absorption) 0.12" (3mm underlayment) – 20% - 25%
  - 2. Ball Rebound (DIN 18032-2): 0.08" (2mm underlayment) – 100%  
0.12" (3mm underlayment) – 100%
  - 3. Flatness: 0.0" +0.029" /-0.0" (0.0mm +0.74mm /-0.0mm)
  - 4. Mar Resistance (GMN3943 GMW14698): Rating 1 – No markings or insignificant damage when scratching, resistance to kick marks and burnishing
  - 5. Abrasion Resistance (ASTM D4060): Less than 185 mg Mass Loss, >500 revolutions wear through, resistance to wear and use
  - 6. Lateral Forgiveness™: +0.045" / -0.0" (+1.14mm / -0.0mm)
- G. Load Bearing Capacity: 220 psi (1.52 MPa)
- H. Dynamic Load - All systems must be able to show verification of passing a minimum 1,000,000 cycles in dynamic load testing with minimum 200 lbs. (91 kg) loading without deviation from flatness specification.
- I. Underlayment – multi-purpose recycled rubber underlayment having a thickness of 0.08" (2.0mm), 0.12" (3mm) and a Durometer of  $60 \pm 5$  on the Shore A scale. Thicker underlayment options are available in the Maple Select™ Response HG™ HR version of this product line.
- J. Retrofit – existing floor systems, synthetic floors must not exceed a maximum thickness of 7mm. Product must have a minimum durometer of  $60 \pm 5$  on the Shore A scale. Flooring representative shall verify that the existing floor system meets these requirements by submitting core samples to the respective manufacturer for analysis and approval.
- K. Sanitary Information
  - 1. Resistance to fungi (when tested in compliance with ASTM G-21 and MIL standard 810-D procedure 508.3). All basic organisms tested (ATCC #6205-11797) and were found to have zero growth.
  - 2. Resistance to the following:
    - a. Bacteria and mildew resistance
    - b. Gram-positive bacterial Staphylococcus Aureus
    - c. Gram-negative Klebsiella Pneumoniae
    - d. Pink-staining organism
    - e. STV Reticulum
    - f. Surface fungi growth prior to and following leaching
- L. Game Line Paint - aliphatic polyurethane as supplied by Sport Court®. Select from available colors.

**PART 3 - EXECUTION**

**3.1 INSPECTION**

- A. Inspect concrete slab for contamination, dryness and levelness. Report any discrepancies to the general contractor.
- B. Concrete slab shall be broom cleaned, mopped and dust free by the general contractor.
- C. Installer (Flooring Contractor) shall document all working conditions as specified in PART 1 – GENERAL prior to starting installation. Report any discrepancies to general contractor.

**3.2 INSTALLATION**

- A. Underlayment – Rubber underlayment shall be unrolled and allowed to relax. All butt joints shall be properly trimmed, fitted, and seamed together with an approved all-purpose tape.
- B. Floor shall be installed to pre-approved layout.
- C. Minimum clearance at all vertical obstructions of 3/4 inch (19mm) is required
- D. Floor surface shall be clean and dust free.
- E. Game Lines
  - 1. Use only high-quality masking tape approved by Sport Court®.
  - 2. Lines shall be painted using Sport Court® recommended aliphatic polyurethane paint.
  - 3. Provide game lines as indicated on drawings.
  - 4. Room temperature shall be >55°F (13°C) and rising during paint installation.
- F. Wall Base (optional) - Install cove base anchored to walls with base cement.
- G. Remove all excess and waste materials from the area of work. Dispose of empty containers in accordance with federal and local statutes.

**END OF SECTION 09624**